

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
 Lab ID: 1211579-002
 Project: WS 0210005
 Matrix: DRINKING WATER

Facility: EP002
 Sample Point: TRT-TAP
 Sample Location: GST
 TCEQ Sample ID: 1211093

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed
ANIONS BY ION CHROMATOGRAPHY			E300.0			Analyst: WR			
Chloride	34.5		300	5.00	5.00	mg/L	5	95747	11/20/2012 12:25:00 AM
Fluoride	0.19		4	0.05	0.05	mg/L	5	95747	11/20/2012 12:25:00 AM
Nitrogen, Nitrate (As N)	0.06		10	0.01	0.05	mg/L	5	95747	11/20/2012 12:25:00 AM
Sulfate	< 5.00		300	5.00	5.00	mg/L	5	95747	11/20/2012 12:25:00 AM
ALKALINITY			SM2320 B			Analyst: KH			
Alkalinity, Bicarbonate (As CaCO ₃)	119	A		2	2	mg/L CaCO ₃	1	95880	11/28/2012
Alkalinity, Carbonate (As CaCO ₃)	< 2	A		2	2	mg/L CaCO ₃	1	95880	11/28/2012
Alkalinity, Hydroxide (As CaCO ₃)	< 2	A		2	2	mg/L CaCO ₃	1	95880	11/28/2012
Alkalinity, Phenolphthalein	< 2	A		2	2	mg/L CaCO ₃	1	95880	11/28/2012
Alkalinity, Total (As CaCO ₃)	119	A		2	2	mg/L CaCO ₃	1	95880	11/28/2012
CONDUCTANCE			SM2510B			Analyst: KH			
Specific Conductance @ 25°C	382			0	0	µmhos/cm	1	95916	11/30/2012
TOTAL DISSOLVED SOLIDS			SM2540C			Analyst: ML			
Total Dissolved Solids (Residue, Filterable)	269		1000	10.0	25.0	mg/L	10	95738	11/20/2012

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
 Lab ID: 1211579-003
 Project: WS 0210005
 Matrix: DRINKING WATER

Facility: EP002
 Sample Point: TRT-TAP
 Sample Location: GST
 TCEQ Sample ID: 1213224

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed
ICP METALS IN DRINKING WATER			E200.7			Analyst: MV			
Calcium	4.14	A		0.0700	0.200	mg/L	1	95957	12/3/2012 12:09:45 PM
Iron	0.115		0.3	0.0200	0.0500	mg/L	1	95957	12/3/2012 12:09:45 PM
Magnesium	1.70			0.0700	0.200	mg/L	1	95957	12/3/2012 12:09:45 PM
Sodium	67.4		20000	0.200	0.500	mg/L	1	95957	12/3/2012 12:09:45 PM
ICPMS METALS IN DRINKING WATER			E200.8			Analyst: SW			
Aluminum	0.00888	J	0.2	0.00400	0.0100	mg/L	1	95915	11/30/2012 12:10:52 PM
Antimony	< 0.000200	J	0.006	0.000200	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Arsenic	< 0.000700	J	0.01	0.000700	0.00200	mg/L	1	95915	11/30/2012 12:10:52 PM
Barium	0.0345		2	0.000700	0.00200	mg/L	1	95915	11/30/2012 12:10:52 PM
Beryllium	< 0.000200	J	0.004	0.000200	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Cadmium	< 0.000400	J	0.005	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Chromium	0.000427	J	0.1	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Copper	0.00102		1.3	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Lead	< 0.000400	J	0.015	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Manganese	0.0256		0.05	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Nickel	< 0.000400	J	0.1	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Selenium	< 0.00100	J	0.05	0.00100	0.00400	mg/L	1	95915	11/30/2012 12:10:52 PM
Silver	< 0.000400	J	0.1	0.000400	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Thallium	< 0.000200	J	0.002	0.000200	0.00100	mg/L	1	95915	11/30/2012 12:10:52 PM
Zinc	0.00452		5	0.00200	0.00400	mg/L	1	95927	11/30/2012 5:09:37 PM
HARDNESS			SM2340 B			Analyst: MV			
Hardness, Calcium/Magnesium (As CaCO ₃)	17.3	N		1.32	1.32	mg/L	1	95960	12/3/2012
MERCURY IN DW			E245.1			Analyst: AE			
Mercury	< 0.000200		0.002	0.000200	0.000200	mg/L	1	95888	11/29/2012 12:42:00 PM

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
 Lab ID: 1211579-006
 Project: WS 0210005
 Matrix: DRINKING WATER

Facility: EP002
 Sample Point: TRT-TAP
 Sample Location: GST
 TCEQ Sample ID: 1215237

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed	
VOLATILES BY GCMS				E524.2			Analyst: BC			
<u>REGULATED COMPOUNDS</u>										
Benzene	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Carbon Tetrachloride	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Monochlorobenzene	< 0.50		100	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
o-Dichlorobenzene	< 0.50		600	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
para-Dichlorobenzene	< 0.50		75	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,2-Dichloroethane	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1-Dichloroethylene	< 0.50		7	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
cis-1,2-Dichloroethylene	< 0.50		70	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
trans-1,2-Dichloroethylene	< 0.50		100	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,2-Dichloropropane	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Ethylbenzene	< 0.50		700	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Dichloromethane	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Styrene	< 0.50		100	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Tetrachloroethylene	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Toluene	< 0.50		1000	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,2,4-Trichlorobenzene	< 0.50		70	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1,1-Trichloroethane	< 0.50		200	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1,2-Trichloroethane	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Trichloroethylene	< 0.50		5	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Vinyl chloride	< 0.50		2	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
m,p-Xylene	< 0.50			0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
o-Xylene	< 0.50			0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Xylenes, Total	< 0.50		10000	0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
<u>UNREGULATED COMPOUNDS</u>										
Chloroform	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
Bromodichloromethane	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
Dibromochloromethane	1.15	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
Bromoform	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
Dibromomethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,3-Dichlorobenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1-Dichloropropene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1-Dichloroethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1,2,2-Tetrachloroethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,3-Dichloropropane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Chloromethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Bromomethane	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,2,3-Trichloropropane	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
1,1,1,2-Tetrachloroethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
Chloroethane	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM	
2,2-Dichloropropane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	
2-Chlorotoluene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM	

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
 Lab ID: 1211579-006
 Project: WS 0210005
 Matrix: DRINKING WATER

Facility: EP002
 Sample Point: TRT-TAP
 Sample Location: GST
 TCEQ Sample ID: 1215237

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed
VOLATILES BY GCMS				E524.2		Analyst: BC			
<u>UNREGULATED COMPOUNDS</u>									
4-Chlorotoluene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Bromobenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
cis-1,3-Dichloropropene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
trans-1,3-Dichloropropene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
1,2,4-Trimethylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
1,2,3-Trichlorobenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
n-Propylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Butyl benzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Naphthalene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Hexachlorobutadiene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
1,3,5-Trimethylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
4-Isopropyltoluene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Isopropylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
tert-Butylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
sec-Butylbenzene	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Trichlorofluoromethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Dichlorodifluoromethane	< 1.00	A		1.00	1.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Bromochloromethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Acetone	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Acrylonitrile	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
2-Butanone (MEK)	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Carbon Disulfide	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Ethyl methacrylate	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
2-Hexanone	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Iodomethane	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Methyl methacrylate	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
4-Methyl-2-pentanone (MIBK)	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Methyl tert-butyl ether (MTBE)	< 0.50	A		0.50	0.50	µg/L	1	95733	11/20/2012 3:56:00 PM
Tetrahydrofuran	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM
Vinyl Acetate	< 5.00	A		5.00	5.00	µg/L	1	95733	11/20/2012 3:56:00 PM

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

Final Analysis Report

LCRA Environmental Laboratory Services

CLIENT:	Wickson Crk SUD	Facility:	EP001
Lab ID:	1211579-001	Sample Point:	TRT-TAP
Project:	WS 0210005	Sample Location:	PUMPHOUSE
Matrix:	DRINKING WATER	TCEQ Sample ID:	1217996

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed
ANIONS BY ION CHROMATOGRAPHY				E300.0					Analyst: WR
Nitrogen, Nitrate (As N)	0.085		10	0.010	0.050	mg/L	5	95697	11/16/2012 11:06:00 PM
Nitrogen, Nitrite	< 0.004	J	1	0.004	0.050	mg/L	5	95697	11/16/2012 11:06:00 PM

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
 Lab ID: 1211579-004
 Project: WS 0210005
 Matrix: DRINKING WATER

Facility: EP001
 Sample Point: TRT-TAP
 Sample Location: PUMPHOUSE
 TCEQ Sample ID: 1214351

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed	
CHLORINATED PESTICIDES				E508.1	(E508)			Analyst: NW		
PCBS										
Aroclor 1016	< 0.07	J	0.5	0.07	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
Aroclor 1221	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
Aroclor 1232	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
Aroclor 1242	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
Aroclor 1248	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
Aroclor 1254	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
PESTICIDES										
Chlordane	< 0.15	J	2	0.15	0.51	µg/L	1	95914	11/29/2012 11:40:36 PM	
PCBS										
Aroclor 1260	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:40:36 PM	
PESTICIDES										
Toxaphene	< 0.51		3	0.51	0.51	µg/L	1	95914	11/29/2012 11:40:36 PM	
ORGANIC COMPOUNDS				E525.2	(E525.2)			Analyst: MS		
PESTICIDES										
Alachlor	< 0.10		2	0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Aldrin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Atrazine	< 0.08	J	3	0.08	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Bromacil	< 0.21	A		0.21	0.21	µg/L	1	95875	11/28/2012 6:06:00 PM	
Butachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
trans-Nonachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Dieldrin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Endrin	< 0.01	J	2	0.01	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Heptachlor	< 0.04	J	0.4	0.04	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Heptachlor epoxide	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Hexachlorobenzene	< 0.08	J	1	0.08	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Hexachlorocyclopentadiene	< 0.08	J	50	0.08	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Lindane	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Methoxychlor	< 0.08	J	40	0.08	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Metolachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Metribuzin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Pentachlorophenol	< 0.04	J	1	0.04	0.51	µg/L	1	95875	11/28/2012 6:06:00 PM	
Propachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
Simazine	< 0.05	J	4	0.05	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
PAHS										
Benzo(a)pyrene	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:06:00 PM	
PHTHALATES										
Di(2-ethylhexyl)adipate	< 0.51	J	400	0.51	2.06	µg/L	1	95875	11/28/2012 6:06:00 PM	
Di(2-ethylhexyl)phthalate	< 0.51	J	6	0.51	2.06	µg/L	1	95875	11/28/2012 6:06:00 PM	

Qualifiers:

A Not Available for Accreditation
 E Value Above Quantitation Range
 J Analyte Detected Below Quantitation Limits
 S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank
 H Holding Time Exceeded
 N Not Accredited
 X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection

LCRA Environmental Laboratory Services

CLIENT: Wickson Crk SUD
Lab ID: 1211579-005
Project: WS 0210005
Matrix: DRINKING WATER

Facility: EP002
Sample Point: TRT-TAP
Sample Location: GST
TCEQ Sample ID: 1214573

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed	
CHLORINATED PESTICIDES				E508.1	(E508)			Analyst: NW		
PCBS										
Aroclor 1016	< 0.07	J	0.5	0.07	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
Aroclor 1221	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
Aroclor 1232	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
Aroclor 1242	< 0.26		0.5	0.26	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
Aroclor 1248	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
Aroclor 1254	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
PESTICIDES										
Chlordane	< 0.16	J	2	0.16	0.52	µg/L	1	95914	11/29/2012 11:59:39 PM	
PCBS										
Aroclor 1260	< 0.08	J	0.5	0.08	0.26	µg/L	1	95914	11/29/2012 11:59:39 PM	
PESTICIDES										
Toxaphene	< 0.52		3	0.52	0.52	µg/L	1	95914	11/29/2012 11:59:39 PM	
ORGANIC COMPOUNDS				E525.2	(E525.2)			Analyst: MS		
PESTICIDES										
Alachlor	< 0.10		2	0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Aldrin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Atrazine	< 0.08	J	3	0.08	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Bromacil	< 0.21	A		0.21	0.21	µg/L	1	95875	11/28/2012 6:33:00 PM	
Butachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
trans-Nonachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Dieldrin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Endrin	< 0.01	J	2	0.01	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Heptachlor	< 0.04	J	0.4	0.04	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Heptachlor epoxide	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Hexachlorobenzene	< 0.08	J	1	0.08	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Hexachlorocyclopentadiene	< 0.08	J	50	0.08	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Lindane	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Methoxychlor	< 0.08	J	40	0.08	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Metolachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Metribuzin	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Pentachlorophenol	< 0.04	J	1	0.04	0.52	µg/L	1	95875	11/28/2012 6:33:00 PM	
Propachlor	< 0.10	A		0.10	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
Simazine	< 0.05	J	4	0.05	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
PAHS										
Benzo(a)pyrene	< 0.02	J	0.2	0.02	0.10	µg/L	1	95875	11/28/2012 6:33:00 PM	
PHTHALATES										
Di(2-ethylhexyl)adipate	< 0.52	J	400	0.52	2.07	µg/L	1	95875	11/28/2012 6:33:00 PM	
Di(2-ethylhexyl)phthalate	< 0.52	J	6	0.52	2.07	µg/L	1	95875	11/28/2012 6:33:00 PM	

Qualifiers:

- A Not Available for Accreditation
- E Value Above Quantitation Range
- J Analyte Detected Below Quantitation Limits
- S Spike Recovery Outside Recovery Limits

- B Analyte Detected in Method Blank
- H Holding Time Exceeded
- N Not Accredited
- X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

Values Below PQL Considered Estimated

LOD: Limit of Detection