

**2021 Annual Drinking Water Quality Report**  
**WICKSON CREEK SUD/ GRIMES PWS#0930003**  
**Annual Water Quality Report for the period of January 1 to December 21, 2021**

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:  
Karen Theiss, Office Manager at 979-589-3030 or [karen@wicksoncreek.com](mailto:karen@wicksoncreek.com)  
Wickson Creek Special Utility District

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono 979-589-3030

**PUBLIC PARTICIPATION OPPORTUNITIES:**

Date: Every 3<sup>rd</sup> Thursday of the month

Time: 6:15 pm

Location: 8770 Hwy 21 East, Bryan, Texas 77808

To learn about future public meetings, concerning your drinking water or to request a schedule of one, please call us.

## **Sources of Drinking Water**

### **WICKSON CREEK SUD GRIMES COUNTY is Ground Water from the Yegu – Jackson Aquefers**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Information about Source Water Assessments

Wickson Creek SUD Grimes County purchases water from Wickson Creek SUD Brazos County. Wickson Creek SUD Brazos County provides purchased ground water from the Carrizo-Wilcox and the Sparta Aquifers located in Brazos County, Bryan Texas.

The TCEQ completed an assessment of your source water and results indicate that some of the sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessment and production efforts at our system contact Karen Theiss at 979-589-3030. For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <https://www.tceq.texas.gov/gis/swaview>. Further details about sources and source-water assessments are available in Drinking Water Watch at URL: <http://dww2.tceq.texas.gov/DWW/>

### Definitions

<b>Action Level:</b>	<b><u>The following tables contain scientific terms and measures, some of which may require explanation.</u></b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>Action Level Goal (ALG):</b>	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.
<b>Avg:</b>	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
<b>Level 1 Assessment:</b>	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
<b>Level 2 Assessment:</b>	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation as occurred and / or why total coliform bacteria have been found in our water system on multiple occasions.
<b>Maximum Contaminant Level or MCL:</b>	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>Maximum Contaminant Level Goal or MCLG:</b>	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
<b>Maximum residual disinfectant level or MRDL:</b>	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>Maximum residual disinfectant level goal or MRDLG:</b>	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>MFL</b>	million fibers per liter (a measure of asbestos)
<b>mrem:</b>	Millirems per year (a measure of radiation absorbed by the body)
<b>na:</b>	not applicable.
<b>NTU</b>	nephelometric turbidity units (a measure of turbidity)
<b>pCi/L</b>	picocuries per liter (a measure of radioactivity)
<b>ppb:</b>	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
<b>ppm:</b>	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
<b>ppt</b>	parts per trillion, or nanograms per liter (ng/L)
<b>ppq</b>	parts per quadrillion, or picograms per liter (pg/L)
<b>Treatment Technique or TT:</b>	A required process intended to reduce the level of a contaminant in drinking water.

This page list all of the federally regulated or monitored contaminants which may have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

### 2021 WATER QUALITY TEST RESULTS

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2021	12	10.5 – 11.5	None	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2021	63	55.3 – 62.9	None	80	ppb	N	By-product of drinking water disinfection.

The value in the Highest Level or Average Detected column is the highest average of all HAA5 & TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2019	0.0195	0.0195 – 0.0195	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2020	0.11	0.11 – 0.11	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2021	0.11	0.0 – 0.11	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2019	4.1	4.1 – 4.1	50	50	ppd	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2021	5.1	5.1 – 5.1	0	50	pCi/L	N	Decay of natural and man-made deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

**Lead and Copper Definitions: Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2020	1.3	1.3	0.381	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2020	0	15	2.36	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Likely Source of Contamination
Chlorine	2021	1.5	1.4	1.7	4	4	MC/L	N	Water additive used to control microbes.

Violations: None